

**Section 2505.2.5 Automotive Vehicles: Equipment in Exhibit Halls.** Add Section:

The operator of and exhibitors at premises used as a place of exhibition may display automotive vehicles and equipment inside a structure if:

1. The amount of fuel in the vehicle or equipment fuel tanks is limited to the greater of:
  1. The minimum amount adequate for vehicle positioning; or
  2. No more than two (2) gallons;
- (b) Vehicle or equipment tanks are effectively locked or adequately sealed;
- (c) Vehicle or equipment battery cables are disconnected from the ignition systems;
- (d) Vehicle or equipment ignition keys are possessed at all times by a responsible person at the display location;
- (e) Vehicle operation is limited to brief parade type displays as specifically approved by the Fire Marshal;
- (f) Show vehicles with LPG tanks shall not be permitted inside the exhibit halls.

MORE FIRE CODE REGULATIONS ARE AVAILABLE ON THE CITY OF SAN ANTONIO WEB SITE [www.sanantonio.gov/safd/codes](http://www.sanantonio.gov/safd/codes)